



Compliance Statement

ISO/IEC, EN & TIA Screened Class E / Category 6 Three Connector Permanent Link

Reichle & De-Massari AG
Binzstrasse 32
CHE-8620 Wetzikon, Switzerland

Compliance Statement No. 0473-3P-1190963

This type of Class E / Category 6 screened three connector permanent link has been tested by 3P Third Party Testing and complies with the Class E requirements of Edition 1.0 of ISO/IEC 11801-1:2017 and CENELEC EN 50173-1:2018, and Category 6 requirements of ANSI/TIA 568.2-D:2018. The Compliance Statement is valid for the permanent link type in T568A designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The permanent link consists of the following Reichle & De-Massari components, and when connected with RJ 45 plugs as from Reichle & De-Massari cords, P/N R302334 and R302335:

Cables: Horizontal Cable, P/N R305649, R308247, R310488, R319412, R813847, R825755, R833675, R844117, R844118, R844119, R845863, R837024, R837029, R848276


Flexible Cable, from cord, P/N R307093
Qualification Status: Manufacturer Verified

Conn. Hardw.: Connection Module, Connection Module Cat. 6 RJ45/s having preformed Inlay Conductors
Qualification Status: Manufacturer Verified


Cords: 10,0m Consol. Cord, P/N R307093
Qualification Status: Manufacturer Verified

Hoersholm, 16th December 2019

Hoersholm, 16th December 2019



Ole Lambertsen
Test Responsible



Jens Rytter Petersen
General Manager