



# Compliance Statement

## ISO/IEC, EN & TIA Unscreened Class E<sub>A</sub> / Category 6A Three Connector Permanent Link

**Reichle & De-Massari AG**  
**Binzstrasse 32**  
**CHE-8620 Wetzikon, Switzerland**

**Compliance Statement No. 0473-3P-1190947**

*This type of Class E<sub>A</sub> / Category 6A unscreened three connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E<sub>A</sub> requirements of Edition 1.0 of ISO/IEC 11801-1:2017 and CENELEC EN 50173-1:2018, and Category 6A requirements of ANSI/TIA 568.2-D:2018. The Compliance Statement is valid for the permanent link type in T568A designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The permanent link consists of the following Reichle & De-Massari components, and when connected with RJ 45 plugs as from Reichle & De-Massari cords, P/N R509872, R509873 and R509874:*

<i>Cables:</i>	<i>Horizontal Cable,</i>	<i>P/N R804268, R804269, R809764, R814611, R815142, R824373, R833674</i>
	<i>Flexible Cable,</i>	<i>from cord, P/N R813789</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardw.:</i>	<i>Connection Module,</i>	<i>Connection Module cat. 6A EL RJ45/u</i>
		<i>having PCB marking 001-9099B</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Cords:</i>	<i>10,0m Consolidation Cord,</i>	<i>P/N R813789</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 13<sup>th</sup> December 2019

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", is written over a horizontal line.

Ole Lambertsen  
Test Responsible

Hoersholm, 13<sup>th</sup> December 2019

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", is written over a horizontal line.

Jens Rytter Petersen  
General Manager