



Compliance Statement

ISO/IEC, EN & TIA Unscreened Class D / Category 5e Four Connector Channel

Reichle & De-Massari AG
Binzstrasse 32
CHE-8620 Wetzikon, Switzerland

Compliance Statement No. 0473-3P-1190933

This type of Class D / Category 5e unscreened four connector channel has been tested by 3P Third Party Testing and complies with the Class D requirements of Edition 1.0 of ISO/IEC 11801-1:2017 and CENELEC EN 50173-1:2018, and Category 5e requirements of ANSI/TIA 568.2-D:2018. The Compliance Statement is valid for the channel type in T568A designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The channel consists of the following Reichle & De-Massari components:

<i>Cables:</i>	<i>Horizontal Cables, Flexible Cable,</i>	<i>P/N R35044, R35045, R35291, R35292, R302285 from cords, P/N R305020, R305022, R307084 and R323251</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardw.:</i>	<i>Connection Module,</i>	<i>Connection Module Cat. 5e RJ45/u having preformed Inlay Conductors</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Cords:</i>	<i>3,0m and 10,0m Consolidation Cords, P/N R323251 and R307084 2,0m and 5,0m Patch cords,</i>	<i>P/N R305020 and R305022</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 29th November 2019

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", is written over a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 29th November 2019

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", is written over a horizontal line.

Jens Rytter Petersen
General Manager