



Compliance Statement

ISO/IEC, EN & TIA Unscreened Class E / Category 6 Three Connector Permanent Link

Reichle & De-Massari AG
Binzstrasse 32
CHE-8620 Wetzikon, Switzerland

Compliance Statement No. 04173-3P-1190938

This type of Class E / Category 6 unscreened three connector permanent link has been tested by 3P Third Party Testing and complies with the Class E requirements of Edition 1.0 of ISO/IEC 11801-1:2017 and CENELEC EN 50173-1:2018, and Category 6 requirements of ANSI/TIA 568.2-D:2018. The Compliance Statement is valid for the permanent link type in T568A designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The permanent link consists of the following Reichle & De-Massari components, and when connected with RJ 45 plugs as from Reichle & De-Massari cords, P/N R302312 and R302314:

<i>Cables:</i>	<i>Horizontal Cable,</i>	<i>P/N R35056, R35057, R305283, R317603, R317604, R802920, R809796, R809797, R814603, R820801, R842467, R813808, R845864, R842468, R861314, R821301</i>
	<i>Flexible Cable,</i>	<i>from cord, P/N R307090</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardw.:</i>	<i>Connection Module,</i>	<i>Connection Module Cat. 6 RJ45/u having preformed Inlay Conductors</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Cords:</i>	<i>10,0 m Consolidation Cord,</i>	<i>P/N R307090</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 12th December 2019

Hoersholm, 12th December 2019

Ole Lambertsen
Test Responsible

Jens Rytter Petersen
General Manager