



Compliance Statement

ISO/IEC, EN & TIA Screened Class E_A / Category 6A Three Connector Permanent Link

Reichle & De-Massari AG
Binzstrasse 32
CHE-8620 Wetzikon, Switzerland

Compliance Statement No. 0473-3P-1190953


This type of Class E_A / Category 6A screened three connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E_A requirements of Edition 1.0 of ISO/IEC 11801-1:2017 and CENELEC EN 50173-1:2018, and Category 6A requirements of ANSI/TIA 568.2-D:2018. The Compliance Statement is valid for the permanent link type in T568A designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The permanent link consists of the following Reichle & De-Massari components, and when connected with RJ 45 plugs as from Reichle & De-Massari cords, P/N R509861, R509862 and R509863:

*Cables: Horizontal Cable, P/N R806969
 Flexible Cable, from cord, P/N R813788
 Qualification Status: Manufacturer Verified*

*Conn. Hardw.: Connection Module, Connection Module Cat. 6A EL RJ45/s
 Qualification Status: having PCB marking 001-9098B
 Manufacturer Verified*

*Cords: 10,0m Consolidation Cord, P/N R813788
 Qualification Status: Manufacturer Verified*

Hoersholm, 13th December 2019



Ole Lambertsen
Test Responsible

Hoersholm, 13th December 2019



Jens Rytter Petersen
General Manager