



# Compliance Statement

## ISO/IEC, EN & TIA Screened Class E<sub>A</sub> / Category 6A Four Connector Channel


**Reichle & De-Massari AG**  
**Binzstrasse 32**  
**CHE-8620 Wetzikon, Switzerland**

**Compliance Statement No. 0473-3P-1190954**

*This type of Class E<sub>A</sub> / Category 6A screened four connector channel has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E<sub>A</sub> requirements of Edition 1.0 of ISO/IEC 11801-1:2017 and CENELEC EN 50173-1:2018, and Category 6A requirements of ANSI/TIA 568.2-D:2018. The Compliance Statement is valid for the channel type in T568A designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The channel consists of the following Reichle & De-Massari components:*

<i>Cables:</i>	<i>Horizontal Cable, Flexible Cable,</i>	<i>P/N R806969 from cords, P/N R509861, R509862, R509863, R813788, R813803</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardw.:</i>	<i>Connection Module,</i>	<i>Connection Module Cat. 6A EL RJ45/s having PCB marking 001-9098B</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Cords:</i>	<i>3,0m and 10,0m Consolidation Cords, P/N R813803 and R813788 2,0m and 5,0m Patch cords,</i>	<i>P/N R509861 and R509863 Manufacturer Verified</i>

Hoersholm, 13<sup>th</sup> December 2019

  
\_\_\_\_\_  
Ole Lambertsen  
Test Responsible

Hoersholm, 13<sup>th</sup> December 2019

  
\_\_\_\_\_  
Jens Rytter Petersen  
General Manager